

October 2, 2025

Mr. Edison Shen
Regulatory Affairs Manager
Midea - North America Technical Service Center
Midea Industrial City, Beijiao
528311 Shunde Foshan, Guangdong, PR. CH

**SUBJECT: VENTURA COUNTY APCD RULE 74.22 - CERTIFICATION OF NATURAL-GAS
FIRED, FAN-TYPE CENTRAL FURNACES**

Dear Mr. Shen,

Per your request, the six Midea and Bosh Furnace Models listed in your Compliance Report dated August 27, 2025, are certified for sale and installation in Ventura County. The approved Midea and Bosh units' Model Numbers are provided in the attached table. This certification is pursuant to Ventura County Air Pollution Control District (APCD) Rule 74.22, Natural Gas-Fired Fan-Type Central Furnaces. The units in the attached table are certified to oxides of nitrogen (NOx) emission limits of not more than 40 nanograms per joule (ng/J).

The Ventura County APCD does not endorse or guarantee any specific product or manufacturer. Modification of the products listed above will void this certification. The model number of the furnace complying with APCD Rule 74.22 shall be displayed on the shipping carton and rating plate.

If you have questions regarding this matter, please contact me at (805)303-3704.

Sincerely,

Ed Swede
Compliance Engineer
Ventura County Air Pollution Control District

**Ventura County APCD
Natural Gas-Fired Fan-Type Central Furnaces**

**Midea and Bosh Certified Units
August 27, 2025**

Tested Midea Model (Shown on the test report)	Bosh Labeled Model (Shown on the rating plate)	Tested Heat Maximum Input (Btu/hr)	Tested Heat Minimum Input (Btu/hr)	Source Test Results (ηg/J) (Average of 3 Runs)
MGV97U120D5A	BGH97M120D5A	119,749	78,706	37.8
MGV97U100D5A	BGH97M100D5A	99,582	64,554	36.7
MGV97U100C5A	BGH97M100C5A	99,214	64,391	37.1
MGV97U080C4A	BGH97M080C4A	79,010	51,896	34.3
MGV80M080B3A	BGH97M080B3A	80,497	51,890	34.9
MGV80M060B3A	BGH97M060B3A	60,070	39,485	39.0

Midea 20250904 74.22